Ref. Certif. No.

NL-126507

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic control gear for LED modules
Name and address of the applicant	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the manufacturer	Signify Netherlands B.V. High Tech Campus 48, 5656 AE Eindhoven, Netherlands
Name and address of the factory	
When more than one factory	☒ Additional information on page 3
Ratings and principal characteristics	**Product data** Ratings: Xi FP 22W 0.2-0.7A SNLDAE 230V S175 sXt: Uin: 220-240 Vac; Iin: 0,12-0,11 Aac; Uin:186-250 Vdc; Iin: 0,09-0,006 Adc; Pin: 26 W; fn: 50/60 Hz or DC; PF: 0,95; Irated: 200-700 mA; Prated: 22 W; Uoutput: 16-48 Vdc, Uout: 70 Vdc max; ta: -40…+55 °C; tc: 85 °C; Built-in; SELV Xi FP 22W 0.3-1.0A SNLDAE 230V S175 sXt: Uin: 220-240 Vac; Iin: 0,12-0,11 Aac; Uin:186-250 Vdc; Iin: 0,09-0,006 Adc; Pin: 26 W; fn: 50/60 Hz or DC; PF: 0,95; Irated: 300-1050 mA; Prated: 22 W; Uoutput: 8-32 Vdc, Uout: 50 Vdc max; ta: -40…+55 °C; tc: 85 °C; Built-in; SELV Xi FP 40W 0.2-0.7A SNLDAE 230V S175 sXt: Uin: 220-240 Vac; Iin: 0,21-0,19 Aac; Uin:186-250 Vdc; Iin: 0,15-0,01 Adc; Pin: 46 W; fn: 50/60 Hz or DC; PF: 0,95; Irated: 200-700 mA; Prated: 40 W; Uoutput: 25-77 Vdc, Uout:100 Vdc max; ta: -40…+55 °C; tc: 85 °C; Built-in; SELV Xi FP 40W .2-.7A SNLDAE 230 S175 TR sXt: Uin: 220-240 Vac; Iin: 0,21-0,19 Aac; fn: 50/60 Hz; Pin: 46 W; PF: 0,95; Iout: 200-700 mA; Pout: 40 W; output voltage: 25-77 Vdc, Uout:100 Vmax; ta: -40…+55 °C; tc: 85 °C; Built-in; SELV

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-05

Signature: May Liu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

	Xi FP 40W 0.3-1.0A SNLDAE 230V S175 sXt: Uin: 220-240 Vac; Iin: 0,21-0,19 Aac; Uin:186-250 Vdc; Iin: 0,15-0,01 Adc; Pin: 46 W; fn: 50/60 Hz or DC; PF: 0,95; Irated: 300-1050 mA; Prated: 40 W; Uoutput: 20-54 Vdc, Uout: 60 Vdc max; ta: -40…+55 °C; tc: 90 °C; Built-in; SELV
Trademark / Brand (if any)	PHILIPS, SIGNIFY, XITANIUM or ADVANCE
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Xi FP 22W 0.2-0.7A SNLDAE 230V S175 sXt, Xi FP 22W 0.3-1.0A SNLDAE 230V S175 sXt, Xi FP 40W .2-.7A SNLDAE 230 S175 TR sXt, Xi FP 40W 0.2-0.7A SNLDAE 230V S175 sXt and Xi FP 40W 0.3-1.0A SNLDAE 230V S175 sXt
Additional information	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 and IEC 62384:2020 National differences: AU, EU Group Differences, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	6271283.50(A-B) and 6271283.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-05

Signature: May Liu

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-06-05

Signature: May Liu